CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION OFFICE OF THE STATE FIRE MARSHAL

FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM





LISTING No. 7165-1703:0172 Page 1 of 1

CATEGORY: Fire Alarm Control Unit (Commercial)

LISTEE: GAMEWELL-FCI, 12 Clintonville Road, Northford, CT 06410

Contact: Brian Reynolds (203) 484-6124 Fax (203) 484-7309

Email: brian.reynolds2@honeywell.com

DESIGN: Models GIF100 and GIF100G fire alarm control units. Automatic, manual, waterfowl,

sprinkler supervisory, local, remote station (PPU), and central station (PPU) services. Refer to the listee's data sheet for additional detailed product description and operational

considerations System components:

BB-26; Battery Boxes

IPDACT-2/-2UD; IP Fire Alarm Communicator HFS-MM; Addressable Mini-Monitor Module HFS-MR; Addressable Relay Module

FCI-LBB; Battery Boxes

M7-AF; Addressable dual action manual pull station

RATING: 120 VAC or 230 VAC primary, 24 VDC secondary

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and

ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as fire alarm control units suitable for high-rise applications when used in

conjunction with separately listed compatible initiating and indicating devices. These control units can generate the distinctive three-pulse Temporal Pattern Fire Alarm Evacuation Signal as required per NFPA 72, 2002 Edition. Refer to manufacturer's

Installation Manual for details.

This control unit meets the requirements of UL Standard 864, 9th Edition.

NOTE: 1. For Fire Alarm Verification Feature (Delay of fire alarm), the maximum

Retard/Reset/Restart period must be adjusted to 30 seconds or less.

XLF: 7165-0559:0165

06-03-10 fm



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: June 09, 2010 Listing Expires June 30, 2010

Authorized By: FRANCIS MATEO, Program Coordinator

Fire Engineering Division